




PLAN OF BACK COUNTER


OM-1 ITEM No.38 ONE REQ'D SCALE 3/4"=1'-














SCALE 3/4"=1'-0"



GOVERNMENT BUILDING, DENVER COLORADO

ERMIGE HOPKINS FOODSERVICE SPECIALIST, INC.

PROJECT NO.

GBDEN

9/22/11

3/4"=1'-0"

SHEET NO.


HFS2145-DM1


of 7 sheet

SCALE:

DRAWN BY

CHECKED BY







LOAD CENTER DIAGRAM

CONVENIENCE OUTLET 120v 16 5-20R 15.0 1P 20A 3 4 1P 20A 12.9 5-15P 120v 16 120v 16		SERVICE	NEMA	L1	L2	L3	TRIP	NO		NO	TRIP	L1	L2	L3	NEMA	SERVICE
120v, 16 5-20R 15.0 20A 5 15.0		120v, 10	GFCI 5-20R	15.0			1P 20A	1		2	1P 20A	10.0				
120v, 1ø 5-20R 15.0 20A 3		CONVENIENCE OUTLET 120v, 1ø	GFCI 5-20R		15.0		1P 20A	3		4	1P 20A		12.9		5-15P	120v, 1ø
120v, 1\(\phi \) 120v, 1\(\phi \) 12.0 1P 20A 9 10.0 1P 20A 9 10.0						15.0	1P 20A	5) 	6	3P /			19.5		
120v, 1ø 5-15P 12.0 20A 9 15.0 1P 20A 1 1 1 1 1 1 1 1 1		120v, 1ø	5-20P	15.0			1P 20A	7		8		14.6				
120v, 1ø		120v, 1ø	5-15P		12.0			9		10			14.6			
120-208v, 1ø, 2980w L14-20P T4.4		120v, 1ø	5-20P			15.0	20A	11		12	30A			18.3		120v, 1ø
24" HEAT LAMP 208v, 1ø, 500w 2.4		HEATED MERCH. GR2SDS-42D 120-208v, 1ø, 2980w	L14-20P	14.4			2P	13		14	15A	4.7				120v, 1ø
208v, 1ø, 500w 2.4 2 17 20 15A 8.3 SPARE	-	0.47 11545 14410			14.4		/	15		16	2P /		8.3			
	- 1					2.4	2P /	17		18	15A			8.3		
SQUARE D $\#$ Q0320L125G LOAD CENTER BOX AND INTERIOR W/ A $\#$ Q0C24UF FLUSH COVER				2.4			15A	19		20						SPARE
		SQUARE D #	£ Q032	20L1	25G	LO	AD CEN	NTER	R BOX AND IN	ΓERI	OR W/	A #	ŧ Q()C2	4UF FL	LUSH COVER

25% SAFETY MARK UP = 98.1AMPS 120/208 3¢ LOAD CENTER

LOAD CENTER DIAGRAM





E BREATH GUARD DETAILS

DM-2 NSF 2010 COMPLIANT SCALE 3/4"=1'-0"

EQUIPMENT BY OTHERS

DUKE LAYOUTS, MEPS, AND LOAD CENTERS ARE BASED ON SPECIFIED MANUFACTURES AND MODELS AS OUTLINED IN THE SPECIFICATIONS IN THE CONTRACT DOCUMENTS. DUKE MUST BE NOTIFIED OF ANY CHANGES TO THE CONTRACT DOCUMENTS IN A TIMELY MANNER.

 NO.
 REVISIONS
 DATE
 BY

 1
 PRELIMINARY SET TO FOODSERVICE CONSULTANT
 9/22/11
 J.G.J.

 2
 REVISED PER CONSULATANTS REQUEST
 10/6/11
 J.G.J.

 3
 4
 10/6/11
 J.G.J.

 6
 6
 6

 7
 8
 6

 9
 9

MANUFACTURING
COMPANY
2305 North Broadway
St. Louis, Mo. 63102
Ph. (314) 231-1130



GOVERNMENT BUILDING, DENVER COLORADO
HOPKINS FOODSERVICE SPECIALIST, INC.

PROJECT NO.

GBDEN


DATE 9/22/11


SCALE: 3/4"=1'-0" DRAWN BY


CHECKED BY
E.B
SHEET NO.

HFS2145-DM2

of 7 SHEET







MANUF,
CON
CON
utions Partner"

e Manufacturing Co.
St. Louis,

ENT BUILDING, DENVER COLORADO

FOODSERVICE HC

FOODSERVIC

PROJECT NO.

9/22/11


SCALE: 3/4"=1'-0" DRAWN BY


CHECKED BY
E.B
SHEET NO.
HFS2145-DM4


of 7 sheet


EQUIPMENT BY OTHERS

DUKE LAYOUTS, MEPS, AND LOAD CENTERS ARE BASED ON SPECIFIED MANUFACTURES AND MODELS AS OUTLINED IN THE SPECIFICATIONS IN THE CONTRACT DOCUMENTS. DUKE MUST BY NOTIFIED OF ANY CHANGES TO THE CONTRACT DOCUMENTS IN A TIMELY MANNER.









PROJECT NO.

GBDEN

9/22/11

3/4"=1'-0"

SHEET NO.


HFS2145-DM5


of 7 sheet


SCALE:


DRAWN BY


CHECKED BY
















MANUFACTURING COMPANY 2305 North Broadway St. Louis, Mo. 63102 Ph. (314) 231-1130



GOVERNMENT BUILDING, DENVER COLORADO
SERVICE HOPKINS FOODSERVICE SPECIALIST, INC.

PROJECT NO.

GBDEN

DATE

9/22/11

SCALE:


3/4"=1'-0"

DRAWN BY


CHECKED BY
E.B
SHEET NO.


HFS2145-DM6


of 7 sheet



SCALE 3/4"=1'-0"







COLORADO PECIALIS

PROJECT NO.

GBDEN 9/22/11

SCALE: 3/4"=1'-0" DRAWN BY

CHECKED BY SHEET NO. HFS2145-DM7

of 7 sheet